DATASHEET - DILM150-XHI22



Auxiliary contact module, 4 pole, $lth=16\,A$, $2\,N/0$, $2\,NC$, Front fixing, Screw terminals, DILM40 - DILM170

XTCEXFBG22



Part no. DILM150-XHI22 Catalog No. 277950

Alternate Catalog No.

EL-Nummer 4130497

(Norway)

Delivery program

Delivery program			
Accessories			Auxiliary contact modules
Description			with interlocked opposing contacts
Function			for standard applications
Number of poles			4 pole
Connection technique			Screw terminals
Rated operational current			
Conventional free air thermal current, 1 pole			
Open			
at 60 °C	I _{th}	Α	16
AC-15			
220 V 230 V 240 V	I _e	Α	6
380 V 400 V 415 V	I _e	Α	4
Contacts			
N/0 = Normally open			2 N/O
N/C = Normally closed			2 NC
Mounting type			Front fixing
Contact sequence			13 L21 L31 L43 14 L22 32 44
For use with			DILM40 DILM50 DILM65 DILM72 DILM80 DILM95 DILM15 DILM150 DILM170 DILM170 DILMP63 DILMP63 DILMP63 DILMP65 DILMP160 DILMP160 DILMF40 DILMF50 DILMF50 DILMF50 DILMF50 DILMF50 DILMF50 DILMF50 DILMF50 DILMF95
Туре			Front mounting auxiliary contact
Instructions			Interlocked opposing contacts according to IEC/EN 60947-5-1 Appendix L, inside the auxiliary contact module Auxiliary contacts used as mirror contacts according to IEC/EN 60947-4-1 Appendix F (not N/C late open)

Technical data

General

donora.			
Standards			IEC/EN 60947, VDE 0660, UL, CSA
Component lifespan			
at U _e = 230 V, AC-15, 3 A	Operations	x 10 ⁶	1.3
Climatic proofing			Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Ambient temperature			
Open		°C	-25 - +60
Enclosed		°C	- 25 - 40
Ambient temperature, storage		°C	- 40 - 80
Mechanical shock resistance (IEC/EN 60068-2-27)			
Half-sinusoidal shock, 10 ms			
Basic unit with auxiliary contact module		g	
N/O contact		g	7
N/C contact		g	5
Degree of Protection			IP20
Protection against direct contact when actuated from front (EN 50274)			Finger and back-of-hand proof
Weight		kg	0.055
Terminal capacities		mm^2	
Screw terminals			
Solid		mm ²	1 x (0.75 - 2.5) 2 x (0.75 - 2.5)
Flexible with ferrule		mm ²	1 x (0.75 - 2.5) 2 x (0.75 - 2.5)
Solid or stranded		AWG	18 – 14
Pozidriv screwdriver		Size	2
Standard screwdriver		mm	0.8 x 5.5 1 x 6
Max. tightening torque		Nm	1.2
Contacts			
Interlocked opposing contacts within an auxiliary contact module (to IEC 60947-5-Annex L)			Yes
N/C contact (not late-break contact) suitable as a mirror contact (to IEC/EN 60947-4-1 Annex F)			DILM40 - DILM170
Rated impulse withstand voltage	U_{imp}	V AC	6000
Overvoltage category/pollution degree			III/3
Rated insulation voltage	Ui	V AC	690
Rated operational voltage	U _e	V AC	500
Safe isolation to EN 61140			
between coil and auxiliary contacts		V AC	440
between the auxiliary contacts		V AC	440
Rated operational current		Α	
Conventional free air thermal current, 1 pole			
at 60 °C	I _{th}	Α	16
AC-15			
220 V 230 V 240 V	l _e	Α	6
380 V 400 V 415 V	l _e	Α	4
500 V	I _e	Α	1.5
DC current			
			Switch-on and switch-off conditions based on DC-13, time constant as specified.
DC L/R ≤ 15 ms			
Contacts in series:		Α	
1	24 V	Α	10
1	60 V	Α	6
1	110 V	Α	3
1	220 V	Α	1
Control circuit reliability	Failure rate	λ	$<\!10^{-8},<$ one failure at 100 million operations (at Ue = 24 V DC, U_{min} = 17 V, I_{min} = 5.4 mA)
Short-circuit rating without welding			
Short-circuit protection maximum fuse			
500 V		A gG/gL	16
Current heat loss at I _{th}			
AC operated		W	3.7

Current heat loss per auxiliary circuit at I _e (AC-15/230 V)		CO	0.5
lating data for approved types			
Auxiliary contacts			
Pilot Duty			
AC operated			A600
DC operated			P300
General Use			
AC		V	600
AC		Α	15
DC		V	250
DC		Α	1

3.7

Design verification as per IEC/EN 61439

DC operated

10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Meets the product standard's requirements. 10.2.7 Inscriptions 10.3.0 Power of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Lepanel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru	Jesign verincation as per ieu/en 01439			
Heat dissipation per pole, current-dependent Equipment heat dissipation, current-dependent Pod W O Stoic heat dissipation, current-dependent Pod W O Stoic heat dissipation, current-dependent Pod W O O Oberating ambient temperature min. Operating ambient temperature max. C O EG/EN 61439 design verification 10.2 Strength of naterials and parts 10.2 Corrosion of stemant stability of enclosures 10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violat (UV) radiation 10.2 Studing 10.2 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Gearances and creapage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.1 Short-circuit rating 10.1 Short-circuit rating 10.1 The panel builder 's responsibility. The panel builder 's responsibility. The panel builder's responsibility. The specifications for the switchgear in the instructions observed. In the panel builder's responsibility. The specifications for the switchgear in the instructions observed. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instructions and the surface observed.	Technical data for design verification			
Equipmen heat dissipation, current-dependent Pod W 0 Static heat dissipation, non-current-dependent Pos W 0 Operating ambient temperature min. C - 25 Operating ambient temperature max. C 6 EEC/FM 61433 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3 I Verification of thermal stability of enclosures 10.2.3 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-wiolet (UV) radiation 10.2 Strength of materials and parts 10.2.5 Liming 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2 Strength of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Insulation properties 10.1 Short-circuit rating 10.1 Short-circuit rating 10.1 Short-circuit rating 10.1 Electromagnetic compatibility 10.1 Short-circuit rating 10.1 Mechanical function 10.1 Mechanical function 10.1 Heap and builder's responsibility. The specifications for the switchgear needs to be evaluated. Is the panel builder's responsibility. The specifications for the switchgear need so because observed. 10.1 Short-circuit rating 10.1 Electromagnetic compatibility 10.1 Short-circuit rating 10.10 Mechanical function 10.11 Mechanical function	Rated operational current for specified heat dissipation	In	Α	4
Static heat dissipation, non-current-dependent Heat dissipation capacity Poiss W Operating ambient temperature min. Operating ambient temperature in min. Operating ambient temperature min. Operating ambient temperature in min. Operating advice the device standard's requirements. Operating ambient mineral standard's requirements. Operating ambient temperature in education of existence of insulating materials to abnormal heat the product standard's requirements. Operating ambient temperature in education of texting and connections Operating ambient temperature in education of existence of insulating materials to abnormal heat the product standard's requirements. Operating ambient temperature in education of texting ambient of the temperature in education of existence of insulating materials to abnormal heat temperature in education of existence of insulating ambient in substing ambient in substing ambient in substing amb	Heat dissipation per pole, current-dependent	P _{vid}	W	0.23
Heat dissipation capacity P _{diss} W 0 Operating ambient temperature min. Operating ambient temperature max. CECIN 61438 design verification 10.2 Strength of materials and parts 10.2.2 Strength of materials and parts 10.2.2 Strength of materials and parts 10.2.3 Verification of termal stability of enclosures 10.2.3 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Litting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Insulation properties 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.13 Mechanical function 10.14 Device meets the requirements provided the information in the instru	Equipment heat dissipation, current-dependent	P _{vid}	W	0
Operating ambient temperature min. Operating ambient temperature max. CC 60 EVEN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3 I Verification of termal stability of enclosures 10.2.3 I Verification of termal stability of enclosures 10.2.3 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to Insulating materials to abnormal heat and fire due to internal electric effects 10.2.5 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBUES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.5 Protection signist electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instru	Static heat dissipation, non-current-dependent	P _{vs}	W	0
Deparating ambient temperature max. ### CC 60	Heat dissipation capacity	P _{diss}	W	0
ECFN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat 10.2.4 Resistance to ultra-violat (UV) radiation 10.2.4 Resistance to ultra-violat (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Incorporation of switching devices and components 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 September 10.9 Power-frequency electric strength 10.9 September 20.9 Power-frequency electric strength 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function	Operating ambient temperature min.		°C	-25
10.2 Strength of materials and parts 10.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.7 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Testing of enclosures made of insulating material 10.9 The panel builder's responsibility. 10.9 Internal electrical circuits and connections 10.9 Lift panel builder's responsibility. 10.9 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9 Power-frequency electric strength 10.9 Temperature rise 10.9 Power-frequency electric strength 10.9 Internal electrical circuits and connections 1 Is the panel builder's responsibility. 10.9 Internal electrical circuits and connections 1 Is the panel builder's responsibility. The specifications for the switchgear observed. 1 Is the panel builder's responsibility. The specifications for the switchgear observed.	Operating ambient temperature max.		°C	60
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.4.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.4.2 Resistance to ultra-violet (UV) radiation 10.5.5 Lifting 10.5.6 Mechanical impact 10.2.5 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3.0 Degree of protection of ASSEMBLIES 10.3.0 Degree of protection of ASSEMBLIES 10.4.1 Clearances and creepage distances 10.5.7 Protection against electric shock 10.5.7 Protection against electric shock 10.5.7 Internal electrical circuits and connections 10.5.8 Connections for external conductors 10.5 Insurance in external conductors 10.5 Insurance in external conductors 10.5 Insurance in external conductors 10.6 Connections for external conductors 10.9 Lapower-frequency electric strength 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.15 Electromagnetic compatibility 10.10 Temperature rise 10.15 Lifting 10.15 Lifting 10.16 Lifting 10.17 Lifting 10.18 Lifting 10.19 Lifting 10.19 Lifting 10.19 Lifting 10.19 Lifting 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Device meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Lifting 10.6 Lifting 1				
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3. Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Insulation properties 10.9.1 Power-frequency electric strength 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.9 Insulation properties 10.9 Insulation properties 10.9.1 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.4 Testing of enclosures made of insulating material 10.9.5 The panel builder's responsibility. 10.9.6 The panel builder's responsibility. The specifications for the switchgear observed. 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function	10.2 Strength of materials and parts			
10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Insulation properties 10.9 Insulation properties 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. The specifications for the switchgear observed. In the device meets the requirements, provided the information in the instru	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Meethanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The specifications for the switchgear observed. Is the panel builder's responsibility. The specifications for the switchgear observed.	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating Is the panel builder's responsibility. 10.15 the panel builder's responsibility. 10.16 the panel builder's responsibility. 10.17 Internal electrical compatibility Is the panel builder's responsibility. 10.18 the panel builder's responsibility. 10.19 The panel builder's responsibility. 10.10 Temperature rise 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instru	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder is responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru				Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.1 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instru	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility The device meets the requirements, Tend and ard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility.	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Electromagnetic meets to be evaluated. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.5 Protection against electric stronges to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Is the panel builder's responsibility. The specifications for the switchgear observed. Is the panel builder's responsibility. The specifications for the switchgear observed.	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10 sthe panel builder's responsibility. Is the panel builder's responsibility. In panel builder's responsibility. In panel builder's responsibility. The specifications for the switchgear observed. In the panel builder's responsibility. The specifications for the switchgear observed. In the panel builder's responsibility. The specifications for the switchgear observed.	10.2.7 Inscriptions			Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. The specifications for the switchgear observed. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility The device meets the requirements, provided the information in the instru	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder is responsibility. Is the panel builder's responsibility. The specifications for the switchgear observed. Is the panel builder's responsibility. The specifications for the switchgear observed. The device meets the requirements, provided the information in the instru	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 1s the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 1s the panel builder's responsibility. 1o.9.4 Testing of enclosures made of insulating material 1o.10 Temperature rise The panel builder is responsibility. 1o.11 Short-circuit rating Is the panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear observed. Is the panel builder's responsibility. The specifications for the switchgear observed. The device meets the requirements, provided the information in the instru	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Short-circuit mation 10.15 Short-circuit mation 10.16 Short-circuit mation 10.17 Mechanical function 10.18 Short-circuit mation 10.19 Short-circuit mation 10.19 Short-circuit mation 10.10 Temperature mation 10.10 Temperature mation 10.11 Short-circuit mation 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Short-circuit mation 10.15 Short-circuit mation 10.16 Short-circuit mation 10.17 Short-circuit mation 10.18 Short-circuit mation 10.19 Short-circuit mation 10.19 Short-circuit mation 10.10 Temperature mation in the instruction 10.10 Temperature mation in the instruction 10.11 Short-circuit mation 10.12 Short-circuit mation 10.13 Mechanical function 10.14 Short-circuit mation 10.15 Short-circuit mation 10.16 Short-circuit mation 10.17 Short-circuit mation 10.18 Short-circuit mation 10.19 Short-circuit mation 10.19 Short-circuit mation 10.10 Temperature mation 10.10 Temperature mation 10.11 Short-circuit mation 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Short-circuit mation 10.15 Short-circuit mation 10.16 Short-circuit mation 10.17 Short-circuit mation 10.18 Short-circuit mation 10.19 Short-circuit mation 10.19 Short-circuit mation 10.10 Temperature mate builder's responsibility. 10.10 Temperature material 10.10 Temperature material 10.11 Short-circuit mation 10.12 Short-circuit mation 10.13 Short-circuit mation 10.14 Short-circuit mation 10.15 Short-circuit mation 10.16 Short-circuit mation 10.17 Short-circuit mation 10.18 Short-circuit mation 10.19 Short-circuit mation 10.19 Short-circuit mation 10.10 Short-circuit mation 10.10 Short-circuit mation 10.11 Short-circuit mation 10.12 Short-	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Short-circuit requirements, provided the information in the instru	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 15 the panel builder's responsibility. 16 the panel builder's responsibility. 17 The panel builder is responsibility for the temperature rise calculation. Eath provide heat dissipation data for the devices. 18 the panel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function 18 the panel builder's responsibility. The specifications for the switchgear observed. 19 The device meets the requirements, provided the information in the instru	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder is responsibility. The panel builder is responsible for the temperature rise calculation. Eato provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder is responsibility. The panel builder is responsible for the temperature rise calculation. Eath provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eath provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru	10.10 Temperature rise			The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instru	10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switchgear must observed.
	10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switchgear must observed.
iodilot (it) io obbol vod.	10.13 Mechanical function			The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Auxiliary contact block (EC000041)

Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Auxiliary switch block (ecl@ss10.0.1-27-37-13-02 [AKN342013])

Number of contacts as change-over contact 0

Number of contacts as normally open contact		2
Number of contacts as normally closed contact		2
Number of fault-signal switches		0
Rated operation current le at AC-15, 230 V	Α	6
Type of electric connection		Screw connection
Model		Top mounting
Mounting method		Front fastening
Lamp holder		None

Approvals

Product Standards	IEC/EN 60947-4-1; UL 508; CSA-C22.2 No. 14-05; CE marking
UL File No.	E29184
UL Category Control No.	NKCR
CSA File No.	012528
CSA Class No.	3211-03
North America Certification	UL listed, CSA certified
Specially designed for North America	No