DATASHEET - B3.0/5-PKZ0

canana ann ann ann ann

Three-phase busbar link, Protected against accidental contact, short-circuit proof, Ue = 690 V, Iu = 63 A, Circuit-breaker: 5, Unit width 45 mm, Type of electric connection: Fork



Part no. B3.0/5-PKZ0
Catalog No. 232290
Alternate Catalog XTPAXCLKA5

No.

EL-Nummer 4315192

(Norway)

Delivery program

| Product range | | Accessories |
|-----------------|--------|--|
| Accessories | | Three-phase busbar link |
| | | For parallel power feed to several motor-protective circuit-breakers on terminals 1, 3, 5 Protected against accidental contact, short-circuit proof, U_e = 690 V, I_u = 63 A Can be extended by rotating by installation For PKZM0 or PKE12, PKE32 without side mounted auxiliary contacts or voltage releases When mounted on the same DIN rail, PKE12/32 and PKZM0 cannot both be connected to a three-phase commoning link. |
| For use with | | PKZ0, PKE12, PKE32 |
| Circuit-breaker | Number | 5 |
| Length | mm | 225 |
| Unit width | mm | 45 |

Technical data

Main conducting paths

| Rated impulse withstand voltage | U_{imp} | V AC | 6000 |
|---------------------------------------|------------------|------|-------|
| Overvoltage category/pollution degree | | | III/3 |
| Rated operational voltage | U _e | V AC | 690 |
| Rated uninterrupted current | I _u | Α | 63 |

Design verification as per IEC/EN 61439

| Technical data for design verification | | | |
|--|-------------------|----|--|
| Rated operational current for specified heat dissipation | In | Α | 63 |
| Heat dissipation per pole, current-dependent | P _{vid} | W | 2.5 |
| Equipment heat dissipation, current-dependent | P _{vid} | W | 7.5 |
| Static heat dissipation, non-current-dependent | P _{vs} | W | 0 |
| Heat dissipation capacity | P _{diss} | W | 0 |
| Operating ambient temperature min. | | °C | -25 |
| Operating ambient temperature max. | | °C | 55 |
| IEC/EN 61439 design verification | | | |
| 10.2 Strength of materials and parts | | | |
| 10.2.2 Corrosion resistance | | | Meets the product standard's requirements. |
| 10.2.3.1 Verification of thermal stability of enclosures | | | Meets the product standard's requirements. |
| 10.2.3.2 Verification of resistance of insulating materials to normal heat | | | Meets the product standard's requirements. |
| 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects | | | Meets the product standard's requirements. |
| 10.2.4 Resistance to ultra-violet (UV) radiation | | | Meets the product standard's requirements. |
| 10.2.5 Lifting | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 Mechanical impact | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 Inscriptions | | | Meets the product standard's requirements. |
| 10.3 Degree of protection of ASSEMBLIES | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 Clearances and creepage distances | | | Meets the product standard's requirements. |
| 10.5 Protection against electric shock | | | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 Incorporation of switching devices and components | | | Does not apply, since the entire switchgear needs to be evaluated. |

| 10.7 Internal electrical circuits and connections | Is the panel builder's responsibility. |
|--|--|
| 10.8 Connections for external conductors | Is the panel builder's responsibility. |
| 10.9 Insulation properties | |
| 10.9.2 Power-frequency electric strength | Is the panel builder's responsibility. |
| 10.9.3 Impulse withstand voltage | Is the panel builder's responsibility. |
| 10.9.4 Testing of enclosures made of insulating material | Is the panel builder's responsibility. |
| 10.10 Temperature rise | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 Short-circuit rating | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 Electromagnetic compatibility | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 Mechanical function | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |

Technical data ETIM 7.0

Low-voltage industrial components (EG000017) / Phase busbar (EC000215)


Electric engineering, automation, process control engineering / Low-voltage switch technology / Component for low-voltage switching technology / Phase busbar (ecl@ss10.0.1-27-37-13-06

| [ACN992011]) | | |
|--|-----|------|
| Number of phases | | 3 |
| Number of poles | | 3 |
| Suitable for number of devices | | 5 |
| Pitch dimensions | mm | 45 |
| Cross section | mm² | 0 |
| Length | mm | 225 |
| Number of modular spacings | | 0 |
| Rated permanent current lu | Α | 63 |
| Type of electric connection | | Fork |
| Insulated | | Yes |
| Rated surge voltage | kV | 6 |
| Conditioned rated short-circuit current Iq | kA | 0 |
| Max. rated operation voltage Ue | V | 690 |
| Rated short-time withstand current lcw | kA | 0 |
| Suitable for devices with N-busbar | | No |
| Suitable for devices with auxiliary switch | | No |
| | | |

Approvals

| Product Standards | UL 508; CSA-C22.2 No. 14; IEC60947-4-1; CE marking |
|--------------------------------------|--|
| UL File No. | E36332 |
| UL Category Control No. | NLRV |
| CSA File No. | 98494 |
| CSA Class No. | 3211-06 |
| North America Certification | UL listed, CSA certified |
| Specially designed for North America | No |

Dimensions



Additional product information (links)

Motor starters and "Special Purpose Ratings" for the North American market

Busbar Component Adapters for modern Industrial control panels

 $http://www.eaton.eu/ecm/groups/public/@pub/@europe/@electrical/documents/content/pct_3258146.pdf$

http://www.moeller.net/binary/ver_techpapers/ver960en.pdf